

Centra Linear Valve ASV-PAC-1

- D Montageanweisung
- DK Installationsvejledning
- ES Instrucciones de montaje
- F Instructions d'installation
- I Istruzioni di montaggio
- N Installationsinstruktioner
- NL Installatievoorschrift
- P Instruções de montagem
- S Installation instruktioner
- FI Asennusohje
- PL Instrukcja montażu

MOUNTING INSTRUCTIONS

0A.

PACKING FOR:
PACKUNG FÜR:

Ø 6.35 mm

BOURRAGE DE PRESSE ETOUPE POUR:
ANELLI PREMISTOPPA PER:
PAKING VOOR:
PAKING FOR:
TIIVISTE VENTTIILILLE:
PACKNING TILL:
PRENSAESTOPAS PARA:

SAFETY:
SICHERHEIT:
SECURITÉ:
SICUREZZA:
VEILIGHEID:
SÄKERHETSFÖRESKRIFT:
KÄYTTÖVARMUUS:
SIKKERHET:
SEGURIDAD:



VALVES FLANGED
LINEAR - INST.
INSTR.
(MU1B1742GE23)




VALVES THREADED
LINEAR -
INST. INSTR.
(MU1B1743GE23)




0B.

DEx, DIx



XEx, XIx



XFx



DFx



DN15 - DN 32

DN15 - DN 32

1.

ASSEMBLY SEQUENCE
REIHENFOLGE DES ZUSAMMENBAUS
SEQUENCE DE MONTAGE
SEQUENZA D'ASSEMBLAGGIO
MONTAGEVOLGORDE
MONTAGE-RÆKKEFØLGE
MONTASJEREKKEFØLGE
KOKOAMISJÄRJESTYS
HOPSÄTTNING
SECUENCIA DE MONTAJE

2.

Thoroughly remove the grinding paste.
 Schleifpaste gründlich entfernen!
 Retirer soigneusement la pâte abrasive.
 Togliere completamente la pasta abrasiva.
 Slijppasta grondig verwijderen.
 Fjern slibepasten grundigt.
 Slipepastaen fjernes grundigt.
 Poista hiomatana perusteellisesti.
 Ta bort slijpastaen omsorgsfullt.
 Quitar la pasta de pulir esmeradamente.

3.

4.

5.

6.

Valve	Y1 when the valve is closed
Ventil	Y1 bei geschlossenem Ventil
Soupape	Y1 avec la soupape fermée
Valvola	Y1 a valvola chiusa
Ventiel	Y1 bij gesloten ventiel
Ventil	Y1 ved lukket ventil
Ventil	Y1 ved lukket ventil
Venttiili	Y1 suljetussa venttiilissä
Ventil	Y1 vid stängd ventil
Válvula	Y1 con la válvula cerrada
DE, DI	89 mm
XE, XI	107 mm
DFx	89 mm
XFx	107 mm



Manufactured for
 and on behalf of
 Pittway Sàrl, Z.A., La Pièce 4
 1180 Rollet, Switzerland

For more information
homecomfort.resideo.com/europe
 Ademco 1 GmbH, Hardhofweg 40,
 74821 MOSBACH, GERMANY
 Phone: +49 6261 810
 Fax: +49 6261 81309